

Public Health & Protection  
East Lothian Council  
Council Offices  
Haddington  
EH41 3HA

Date of Issue: 26 October 2020

## TEST REPORT

For the attention of: Lynn Crothers

### The Water Intended for Human Consumption (Private Supplies) (Scotland) Regulations 2017

Laboratory Reference: 50539288/0/1

Taken by C Paterson on 07/10/2020

Client Reference: 20EL173A

Received on 07/10/2020

Sample Description: Purely Scottish Factory, Private Water Supply

Sample type: Private Water Supply - 2017

Sampling Point: Purely Scottish Factory, Private Water Supply

Parameter	Method	Units	Result	Maximum limit
* Appearance	W/001	-	Clear	
* Colour	W/021	mg/l Pt/Co	< 2	20
Date Analysis Complete			15/10/20	
Turbidity	W/022	N.T.U.	0.6	4.0
* Odour	W/001	-	None	
* Taste	W/002	-	Not tested	
pH	W/003	-	7.85	6.50 to 9.50
* Copper	W046	mgCu/L	< 0.01	2.00
* Manganese	W046	µgMn/L	< 0.9	50.0
* Zinc	W046	µgZn/L	24.1	
* Iron	W046	µgFe/L	6.0	200.0
* Nickel	W046	µgNi/L	2.54	20.00
Lead	W015	µgPb/L	< 1	10

**Observation** (These do not form part of the accredited tests)

The test results comply with the requirements of the above regulations for potable drinking water.

ROBERT C BEATTIE

Scientific Bereavement & Registration Services Senior Manager  
Edinburgh Scientific Services

4 Marine Esplanade, Edinburgh EH6 7LU Tel 0131 555 7980, Fax: 0131 555 7987

Email: scientific.services@edinburgh.gov.uk



1005



INVESTORS  
IN PEOPLE



CUSTOMER  
SERVICE  
EXCELLENCE

Signed: 

Dr Charles Veitch : Team Leader/Technical Manager

The sample was examined under my direction, according to documented standard and in-house methods (Note 2) , details of which are available on request.

This laboratory is accredited in accordance with the recognised International Standard ISO/IEC 17025. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer joint ISO-ILAC-IAF communiqué dated April 2017).

- Notes:
1. No liability can be accepted for information given by customer
  2. Non-accredited tests are indicated by "\*\*\*"
  3. Subcontracted tests are indicated by "#"
  4. This report must not be reproduced except in full without written approval of the laboratory



ROBERT C BEATTIE  
Scientific Bereavement & Registration Services Senior Manager  
Edinburgh Scientific Services  
4 Marine Esplanade, Edinburgh EH6 7LU Tel 0131 555 7980, Fax: 0131 555 7987  
Email: scientific.services@edinburgh.gov.uk

